

The DCP P.R carriage Factory Islamabad

Dated: 25-08-26

The ACP P.R Carriage Factory Islamabad

Subject: Clarification Required Circuit Breaker Specification 2CF/4P/0846-D/2026

Dear Sir,

Kindly clarify the circuit breaker specification mentioned in the tender. The 6A, 10A and 16 A single pole 230Volt breaker are normally MCBs (Miniature Circuit breakers) not MCCBs.

Similarly the 33A Triple pole breaker specification may require clarification regarding the exact standard rating and type (MCB/MCCB).

Kindly confirm whether your requirement is MCB or MCCB along with the exact current rating and Voltage, so that we can quote the correct material as per Pakistan railways Requirement.

Sincerely Yours
DEZILER ENGINEERING




DEZILER ENGINEERING
1145 Commercial Area, Phase-1 Defence Housing Society
Lahore Cantt PH: +92-42-37121558 Mob: 0092-333-4743020
GST No: 30719PND134
Email: dezilerengineering@gmail.com